



KEY NOTES:

- ① FLOW METER (REFER TO DIVISION 33 FOR SPECIFICATION)
- ② ISOLATION VALVE
- ③ PRESSURE TAP (AS NEEDED PER PROJECT)
- ④ TEMPERATURE TAP (AS NEEDED PER PROJECT)
- ⑤ POWER – FROM POWER SOURCE PER MANUFACTURER REQUIREMENTS
- ⑥ SIGNAL – TO BUILDING ELECTRICAL METER (SEE BUILDING ELECTRICAL METER CONNECTION DIAGRAM DETAILS)
- ⑦

MINIMUM STRAIGHT PIPE DIMENSIONS ARE BASED ON GENERAL INDUSTRY GUIDELINES. VERIFY EXACT REQUIREMENTS WITH EQUIPMENT MANUFACTURER.

<b>UNIVERSITY OF CALIFORNIA, DAVIS</b>		
TYPICAL STEAM METER		
REVISION: 0		
SCALE: NONE	DATE: JULY 2011	
DWN: EY	APPROVED	FILE NO.
CHK: VG		ST-06