



KEY NOTES:

- ① FLOW METER (REFER TO DIVISION 33 FOR SPECIFICATION)
- ② ISOLATION VALVE
- ③ POWER – FROM POWER SOURCE PER MANUFACTURER REQUIREMENTS
- ④ SIGNAL – TO BUILDING ELECTRICAL METER (SEE BUILDING ELECTRICAL METER CONNECTION DIAGRAM DETAILS)
- ⑤

MINIMUM STRAIGHT PIPE DIMENSIONS ARE BASED ON GENERAL INDUSTRY GUIDELINES. VERIFY EXACT REQUIREMENTS WITH EQUIPMENT MANUFACTURER.

UNIVERSITY OF CALIFORNIA, DAVIS

TYPICAL
CONDENSATE METER

REVISION: 0

SCALE: NONE

DATE: JULY 2011

DWN: EY

APPROVED

FILE NO.

CHK: VG

ST-07