



KEY NOTES:

- ① BTU METER PROCESSING UNIT
- ② FLOW METER TRANSDUCERS (STRAP ON)
- ③ TEMPERATURE SENSOR (STRAP ON)
- ④ J-BOX
- ⑤ MINIMUM STRAIGHT PIPE DIMENSIONS ARE BASED ON GENERAL INDUSTRY GUIDELINES. VERIFY EXACT REQUIREMENTS WITH EQUIPMENT MANUFACTURER.
- ⑥ SPACING OF TRANSDUCERS PER MANUFACTURER DIRECTION

UNIVERSITY OF CALIFORNIA, DAVIS		
TYPICAL ULTRASONIC FLOW METER		
REVISION: 0		
SCALE: NONE		DATE: JULY 2011
DWN: EY CHK: VG	APPROVED	FILE NO. CW-01