



**NOTES:**

1. CONTRACTOR SHALL LOCATE METER BOXES AND VALVE CANS SO AS NOT TO INTERFERE WITH EXISTING UTILITIES.
2. AVOID EXISTING TREES, ETC.
3. REMOTE VENT PIPE IS NOT REQUIRED FOR CHILLED WATER LINES

**NOTE TO DESIGN PROFESSIONAL:**

1. VERIFY AND EDIT TEXT IN BRACKETS [ ]

<b>UNIVERSITY OF CALIFORNIA, DAVIS</b>		
<b>AIR RELEASE</b>		
REVISION: 2		
SCALE: NONE	DATE: JULY 2011	
DWN: KH CHK: VG	APPROVED	FILE NO. DW-11