



NOTES:

1. CONTRACTOR SHALL LOCATE METER BOXES AND VALVE CANS SO AS NOT TO INTERFERE WITH EXISTING UTILITIES.
2. AVOID EXISTING TREES, ETC.
3. REMOTE VENT PIPE IS NOT REQUIRED FOR CHILLED WATER LINES

NOTE TO DESIGN PROFESSIONAL:

1. VERIFY AND EDIT TEXT IN BREACKETS []