

**DIVISION 04 - MASONRY**

**MASONRY**

**04 00 00**

Exposed masonry shall be sealed (See Division 7) and control joints shall be caulked inside and out before additional wall finish materials are applied.