

## DIVISION 14 – CONVEYING EQUIPMENT

<b>ELEVATORS</b>
------------------

<b>14 20 00</b>
-----------------

### GENERAL REQUIREMENTS

Refer to the University's Standard Specification Section 14 20 11 Elevators.

For buildings over two-stories with substantial equipment located on the rooftop, the Design Professional shall consult the University's Representative to verify requirements for elevator access to the roof for maintenance purposes. If elevator is to extend to the roof, an exit path to the stair shall be required.

For hydraulic elevators, neither hydraulic pump nor motor shall be submersible.

Elevator machine room shall be located adjacent to elevator. Provide hook-up phone line in machine room.

Remote hydraulic stations are not acceptable. If a remote station is required, obtain written approval from University's Representative.

Biodegradable oil may be used, but it must be submitted for approval by the University's Representative.