



NOTES:

1. TOOLED CONTROL JOINT (CJ)
2. 1/2" FIBER EXPANSION JOINT (EJ) WITH ZIP-STRIP TOP
3. TOOLED DEEP CONTROL JOINT (DCJ) SHALL BE ¼ DEPTH OF TOTAL CONCRETE THICKNESS
4. MEDIUM BROOM FINISH
5. EXPOSED AGGREGATE – CACHE CREEK AGGREGATE OR EQUAL

GENERAL NOTES

- A. MINOR PEDESTRIAN WALKS ARE SIMILAR FOR DCJ AND EJ SPACING. CJ SPACING SHALL BE 5'-0"cc MAX. OMIT LONGITUDINAL CJ AND EXPOSED AGGREGATE FINISH
- B. MINOR PEDESTRIAN WALKWAY FINISH SHALL BE MEDIUM BROOM FINISH SWEEPED PERPENDICULAR TO DIRECTION OF PATH
- C. COMPRESSIVE STRENGTH – 3000 PSI MIN.
- D. 1% MIN. AND 2% MAX. CROSS SLOPE
- E. WALKWAY HEIGHT SHALL NOT EXCEED 5% LONGITUDINAL SLOPE WITHOUT COMPLYING WITH THE CBC PROVISIONS FOR PEDESTRIAN RAMPS