



NOTES:

- ① GAS RISER (ANODELESS RISER ON PLASTIC SERVICE LINES)
- ② 3/4" BYPASS VALVE (LUBRICATED PLUG VALVE)
- ③ SHUT-OFF VALVE (LUBRICATED PLUG VALVE)
- ④ TEST PORT (1/4" NPT VALVE WITH PLUG)
- ⑤ DIELECTRIC UNION
- ⑥ GAS PRESSURE REGULATOR (REFER TO DIVISION 33 FOR SPECIFICATIONS)
- ⑦ DIAPHRAGM METER (REFER TO DIVISION 33 FOR SPECIFICATIONS)
- ⑧ SEISMIC SHUT-OFF VALVE (REFER TO DIVISION 33 FOR SPECIFICATIONS)
- ⑨ BYPASS VALVE (MATCH LOW PRESURE PIPE SIZE)
- ⑩ 3/4" SCHEDULE 40 PVC CONDUIT TO BUILDING FOR REMOTE MONITORING.
CONNECT GAS METER TO MAIN BUILDING ELECTRICAL METER WITH BELDEN 5340F1 18-2 WIRE PER STANDARD DETAIL E-03, BUILDING ELECTRICAL METER & UTILITY METER DIAGRAM.
- ⑪ CORD GRIP
- ⑫ MASK AND PAINT ENTIRE ASSEMBLY EXCEPT METER, REGULATOR, AND SEISMIC VALVE