



NOTES:

- ① GAS RISER (ANODELESS RISER ON PLASTIC SERVICE LINES)
- ② 3/4" BYPASS VALVE (LUBRICATED PLUG VALVE)
- ③ SHUT-OFF VALVE (LUBRICATED PLUG VALVE)
- ④ DIELECTRIC UNION
- ⑤ TEST PORT (1/4" NPT VALVE WITH PLUG)
- ⑥ FILTER
- ⑦ REGULATOR (REFER TO DIVISION 33 FOR SPECIFICATION)
- ⑧ METER (REFER TO DIVISION 33 FOR SPECIFICATION)
- ⑨ SEISMIC SHUT-OFF VALVE (REFER TO DIVISION 33 FOR SPECIFICATION)
- ⑩ BYPASS (MATCH LOW PRESSURE PIPE SIZE)
- ⑪ TYPICAL METER ASSEMBLY SUPPORTS
- ⑫ FLEX
- ⑬ 3/4" SCHEDULE 40 PVC CONDUIT TO BUILDING FOR REMOTE MONITORING. CONNECT GAS METER TO MAIN BUILDING ELECTRICAL METER WITH BELDEN 5302F1 18-4 WIRE PER STANDARD DETAIL, BUILDING ELECTRICAL METER & UTILITY METER DIAGRAM.
- ⑭ MASK AND PAINT ENTIRE ASSEMBLY EXCEPT METER, REGULATOR, AND SEISMIC VALVE.