



NOTES:

1. 3/8" FIBER EXPANSION JOINT (EJ) WITH ZIP-STRIP TOP AND FINISHED WITH JOINT SEALANT, WITH SAND GRANULES ADHERED TO SURFACE
2. SCORE JOINT (SJ) SHALL BE 1/4 DEPTH OF TOTAL CONCRETE THICKNESS
3. MEDIUM BROOM FINISH
4. EXPOSED AGGREGATE - MIX DESIGN TO INCLUDE CACHE CREEK AGGREGATE

GENERAL NOTES

- A. MINOR PEDESTRIAN WALKS ARE SIMILAR FOR SJ AND EJ SPACING. SJ SPACING SHALL BE LONGITUDINAL SJ AND EXPOSED AGGREGATE FINISH.
- B. MINOR PEDESTRIAN WALKWAY FINISH SHALL BE MEDIUM BROOM FINISH SWEEPED PERPENDICULAR TO DIRECTION OF PATH
- C. COMPRESSIVE STRENGTH - 3000 PSI MIN.
- D. 1% MIN. AND 2% MAX. CROSS SLOPE
- E. WALKWAY HEIGHT SHALL NOT EXCEED 5% LONGITUDINAL SLOPE WITHOUT COMPLYING WITH THE CBC PROVISIONS FOR PEDESTRIAN RAMPS