



**NOTES:**

1. 500 KVA AND 1000 KVA PAD MOUNTED TRANSFORMERS REQUIRE A WIDTH OF 84", AN ADDITIONAL 6" ON SECONDARY SIDE AS INDICATED.
2. ALL CONDUITS SHALL BE AS FAR LEFT IN SECONDARY AREA AS POSSIBLE.
3. FRONT SHALL BE CLEAR FOR DOOR SWING, AND POSITIONED FOR EASY ACCESS.