



NOTES:

1. BTU METER PROCESSING UNIT
2. FLOW METER TRANSDUCERS (STRAP ON)
3. TEMPERATURE SENSOR (STRAP ON)
4. J-BOX
5. MINIMUM STRAIGHT PIPE DIMENSIONS ARE BASED ON GENERAL INDUSTRY GUIDELINES. VERIFY EXACT REQUIREMENTS WITH EQUIPMENT MANUFACTURER.
6. SPACING OF TRANSDUCERS PER MANUFACTURER DIRECTION

**TYPICAL ULTRASONIC FLOW METER**