



NOTES:

- ① FLOW METER (REFER TO DIVISION 33 FOR SPECIFICATION)
- ② ISOLATION VALVE
- ③ PRESSURE TAP (AS NEEDED PER PROJECT)
- ④ TEMPERATURE TAP (AS NEEDED PER PROJECT)
- ⑤ 3/4" EMT CONDUIT TO ELECTRICAL METER FOR REMOTE MONITORING.
CONNECT STEAM METER TO MAIN BUILDING ELECTRICAL METER WITH BELDEN 5302F1 18-4 WIRE PER STANDARD DETAIL E-03, BUILDING ELECTRICAL METER & UTILITY METER DIAGRAM.
- ⑥ MINIMUM STRAIGHT PIPE DIMENSIONS ARE BASED ON GENERAL INDUSTRY GUIDELINES. VERIFY EXACT REQUIREMENTS WITH EQUIPMENT MANUFACTURER.
- ⑦ REMOTE MOUNTED FLOW CONVERTER