



NOTES:

- ① FLOW METER (REFER TO DIVISION 33 FOR SPECIFICATION)
- ② ISOLATION VALVE
- ③ CORD GRIP
- ④ 3/4" EMT CONDUIT TO ELECTRICAL METER FOR REMOTE MONITORING. CONNECT CONDENSATE METER TO MAIN BUILDING ELECTRICAL METER WITH STRANDED 18/4 WIRE PER STANDARD DETAIL E-03, BUILDING ELECTRICAL METER & UTILITY METER DIAGRAM.
- ⑤ MINIMUM STRAIGHT PIPE DIMENSIONS ARE BASED ON GENERAL INDUSTRY GUIDELINES. VERIFY EXACT REQUIREMENTS WITH EQUIPMENT MANUFACTURER.
- ⑥ CIRCUIT SETTER
- ⑦ CHECK VALVE