



NOTES:

- ① GAS RISER (ANODELESS RISER ON PLASTIC SERVICE LINES)
- ② SHUT-OFF VALVE
- ③ TEST PORT ($\frac{1}{4}$ " NPT VALVE WITH PLUG)
- ④ DIELECTRIC UNION
- ⑤ GAS PRESSURE REGULATOR (REFER TO DIVISION 33 FOR SPECIFICATIONS)
- ⑥ DIAPHRAGM METER (REFER TO DIVISION 33 FOR SPECIFICATIONS)
- ⑦ SEISMIC SHUT-OFF VALVE (REFER TO DIVISION 33 FOR SPECIFICATIONS)
- ⑧ $\frac{3}{4}$ " SCHEDULE 40 PVC CONDUIT TO BUILDING FOR REMOTE MONITORING. CONNECT GAS METER TO MAIN BUILDING ELECTRICAL METER WITH BELDEN 5340F1 18-2 WIRE PER STANDARD DETAIL E-03, BUILDING ELECTRICAL METER & UTILITY METER DIAGRAM.
- ⑨ CORD GRIP
- ⑩ MASK AND PAINT ENTIRE ASSEMBLY ANSI 61 GRAY EXCEPT METER, REGULATOR, AND SEISMIC VALVE